

Media Replacement Schedule - PAS2K

1. H2003 - Ring Panel Coarse Particulate Filter
 - a. High Particulate- every 8 hours
 - b. Medium Particulate- every 48 hours
 - c. Low particulate- every 72 hours or until filter light goes on

2. H2002-12 - (Optional Pleated Particulate Pre-filter)
 - a. Use filter indicator light to determine needs
 - b. High Particulate- estimate 72 hours
 - c. Medium Particulate- 3 x/ month
 - d. Low particulate- 1 x/ month or when filter light goes on

3. VL2024 - (Optional Vapor Lock Carbon Filter)
 - a. Use filter indicator light to determine needs
 - b. High Particulate- estimate 72 hours
 - c. Medium Particulate- 3 x/ month
 - d. Low particulate- 1 x/ month or when filter light goes on

4. H242406-99 - HEPA Filter
 - a. Every 9,000 hours
 - b. 1 year and a half (even if 9,000 hours has not been reached)

5. H2010 - (Optional HEPA filter)
 - a. Every 9,000 hours
 - b. 1 year and a half (even if 9,000 hours has not been reached)

6. H2010M - (Optional HEPA filter)
 - a. Every 9,000 hours
 - b. 1 year and a half (even if 9,000 hours has not been reached)